

# MUNICIPALITY OF ANCHORAGE PURCHASING DEPARTMENT

PHONE (907) 343-4590 P.O. Box 196650 ANCHORAGE, ALASKA 99519-6650

|  |  |
|--|--|
| DATE OF INVITATION<br><b>September 8, 2022</b> | TIME AND DATE OF OPENING<br><b>2:00 PM Local Time, October 6, 2022</b> |
|--|--|

## ADDENDUM No. 1

TO INVITATION TO BID No. 2022C040

DATE ISSUED: September 28, 2022

TITLE: **Performing Arts Center Elevator Modernization.**

The following changes and/or additions are hereby made to subject Invitation to Bid:

1. **CHANGE:** the Time and Date of Opening to: **2:00 PM Local Time, October 6, 2022**
2. **INCORPORATE:** the attached changes, consisting of 1 page, identified as Addendum No. 1, dated September 28, 2022.

All other terms, conditions and specifications remain unchanged.

An electronic (.pdf) copy of the Invitation to Bid is available at Municipality of Anchorage, Purchasing Office website; (<http://www.muni.org/Departments/purchasing/Pages/bidding.aspx>) Should you choose to obtain a copy of the Invitation to Bid from the website; it is your responsibility to periodically check the website for addends.

THIS ADDENDUM MUST BE ACKNOWLEDGED IN SPACE PROVIDED ON BID PROPOSAL SHEET OR SIGNED AND RETURNED TO PURCHASING PRIOR TO TIME SET FOR BID OPENING IN ACCORDANCE WITH ANCHORAGE MUNICIPAL CODE 7.20.020C.

Municipality of Anchorage reserves the right to accept or reject bids. Prices quoted must be F.O.B. Destination. Municipality is exempt from Federal Excise Tax. Bids shall be submitted to the Purchasing Office prior to time set for opening. Any bids not received by the Purchasing Office prior to that time will not be considered and will be returned.

---


PLEASE ACKNOWLEDGE AND RETURN THIS ADDENDUM PRIOR TO THE DATE AND TIME SHOWN ABOVE OR YOUR BID MAY BE REJECTED.

VENDOR NAME \_\_\_\_\_

SIGNATURE \_\_\_\_\_

DATE OF BID \_\_\_\_\_

MUNICIPALITY OF  
ANCHORAGE



Chris Hunter  
Deputy Purchasing Director

**RESPONSES TO BIDDERS' QUESTIONS:**

1. **Question:** Card reader/ security that is to be installed in the elevator. Section 2.3.I Discusses a Card/Proximity Reader Security System to be installed. Is this system required to tie into an existing system in the building? Is there a particular brand or OEM that is preferred or required? Section "I" states to "Provide a filler plate to match card slot size and car return panel finish, including direction of graining, where card slot or proximity reader cutout is not initially utilized." Does this mean a functional card reader is not required at turnover? Please clarify.

**Response:** There is only a need to provide a box and conduit in the car for a future card reader in accordance with the spec. Spare conductors are required under 2.5.G already, so if there is a need to install a card reader the traveler cable would be in place.

**Where any requirements of the Invitation to Bid conflict with an item in an Addendum, the Addendum shall govern. All other terms and conditions of the Invitation to Bid shall remain unchanged and in full force and effect.**

**END OF ADDENDUM NO.1**