

MUNICIPALITY OF ANCHORAGE PURCHASING DEPARTMENT

PHONE (907) 343-4590 P.O. Box 196650 ANCHORAGE, ALASKA 99519-6650

DATE OF INVITATION October 17, 2022	TIME AND DATE OF OPENING 2:00 PM Local Time, November 8, 2022
---	---

ADDENDUM No. 2

TO INVITATION TO BID No. 2022C045

DATE ISSUED: October 28, 2022

TITLE: **GWTF Aeration System & Blower Upgrades.**

The following changes and/or additions are hereby made to subject Invitation to Bid:

- 1. INCORPORATE:** the attached changes, consisting of four pages, identified as Addendum No. 2, dated October 28, 2022.

All other terms, conditions and specifications remain unchanged.

An electronic (.pdf) copy of the Invitation to Bid is available at Municipality of Anchorage, Purchasing Office website; (<http://www.muni.org/Departments/purchasing/Pages/bidding.aspx>) Should you choose to obtain a copy of the Invitation to Bid from the website; it is your responsibility to periodically check the website for addends.

THIS ADDENDUM MUST BE ACKNOWLEDGED IN SPACE PROVIDED ON BID PROPOSAL SHEET OR SIGNED AND RETURNED TO PURCHASING PRIOR TO TIME SET FOR BID OPENING IN ACCORDANCE WITH ANCHORAGE MUNICIPAL CODE 7.20.020C.

Municipality of Anchorage reserves the right to accept or reject bids. Prices quoted must be F.O.B. Destination. Municipality is exempt from Federal Excise Tax. Bids shall be submitted to the Purchasing Office prior to time set for opening. Any bids not received by the Purchasing Office prior to that time will not be considered and will be returned.

PLEASE ACKNOWLEDGE AND RETURN THIS ADDENDUM PRIOR TO THE DATE AND TIME SHOWN ABOVE OR YOUR BID MAY BE REJECTED.

VENDOR NAME _____
ANCHORAGE

MUNICIPALITY OF

SIGNATURE _____

DATE OF BID _____

Chris Hunter
Chris Hunter
Deputy Purchasing Director

**Invitation to Bid No. 2022C045
GIRDWOOD WASTEWATER TREATMENT FACILITY
AERATION SYSTEM & BLOWER UPGRADES**

**Addendum No. 2
October 28, 2022**

TO: PLANHOLDERS

The contract documents for the referenced project are clarified and amended as follows:

BID PROPOSAL MODIFICATIONS:

Item No. 1: **REPLACE** Bid Proposal Sheet BP-1 – BP-2 in its entirety and replace with the attached Bid Proposal Sheets BP-1R – BP-2R, identified as Addendum No 2, dated October 28, 2022.

QUESTIONS AND ANSWERS:

Question1: Are materials on this project required to be AIS compliant (where applicable)? AIS is referenced in section 01 30 00 (Submittal procedures), but nowhere else.

Answer1: American Iron and Steel (AIS) compliance is not a requirement of the project, thus:

- **Delete SECTION 01 30 00, paragraph 1.03, A, 14, in its entirety**
- **Delete SECTION 40 05 07, paragraph 1.04 H, 2, a, in its entirety**

Question2: SP-15 (regarding MASS 60.02, Fittings & Gaskets) states “only carbon steel with hot dip galvanized (HDG) finish nuts, bolts, and washers shall be used”. Technical Specification 40 05 01 (Process Piping) references stainless steel bolts, nuts, washers, in multiple paragraphs/materials (couplings, flanges, etc). – Please clarify where HDG bolts, nuts, washers are permissible for use, and where 316SS is required.

Answer2: Change SECTION 60.02 FURNISH AND INSTALL PIPE, Article 2.3 Materials, I. Fittings and Gaskets to:

Carbon steel with hot dip galvanized (HDG) finish nuts, bolts, and washers shall be used, unless otherwise specified in the Contract Documents.

Question3: Turbo Blowers Section 43 11 21:

- Who is responsible for the cost (travel, lodging, food, etc) of having Owner, Design Engineer, and Owner’s SCADA System Integrator witness factory acceptance testing?
- Can any testing/acceptance be observed remotely (Teams, Zoom, etc.)?

Answer3: Pursuant to SECTION 01 46 50, paragraph 3.04, B, for out of state travel to witness factory testing, the cost of one (1) representative from the OWNER shall be included in the CONTRACTOR’s Lump Sum bid. The cost shall include airfare, ground transportation, and lodging for the duration of FAT. Meals are excluded.

All other out of state travel cost will not be the responsibility of the CONTRACTOR.

It is not acceptable to observe FAT procedures remotely.

**Invitation to Bid No. 2022C045
GIRDWOOD WASTEWATER TREATMENT FACILITY
AERATION SYSTEM & BLOWER UPGRADES**

**Addendum No. 2
October 28, 2022**

Question4: Does the American Iron and Steel requirement apply to this project? I don't see any requirement under the special conditions, but Specification Section 40 05 07 1.04.H.2.a requires documentation of AIS compliance.

Answer4: See answer to Question 1 above.

Where any requirements of the Invitation to Bid are in conflict with an item in an Addendum, the Addendum shall govern.

All other terms and conditions of the Invitation to Bid shall remain unchanged and in full force and effect.

BID PROPOSAL
(CERTIFICATION)

TO: MUNICIPALITY OF ANCHORAGE _____, 2022
PURCHASING DEPARTMENT
632 W. 6TH AVENUE, SUITE 520
ANCHORAGE, ALASKA 99501

SUBJECT: Invitation to Bid No. 2022C045

PROJECT TITLE: GWTF Aeration System and Blower Upgrades Project (WM.00159)

Pursuant to and in compliance with subject Invitation to Bid, and other bid documents relating thereto, the bidder hereby proposes to furnish all labor and materials and to perform all work for the construction of the above referenced project in strict accordance with the bid documents at the prices established in the Bid Proposal, page BP- 1 of 2 through BP- 2 of 2 submitted herewith.

The bidder agrees, if awarded the contract, to commence and complete the work within the time specified in the bid documents.

BASIC BID; LUMP SUM \$ _____

Company name/manufacturer of high-speed turbo (HST) blower equipment proposed*: _____

* No substitutions of the turbo blower manufacturer will be allowed after bid opening, unless approved in writing by the OWNER. Naming the turbo blower equipment manufacturer will not influence the bid results, provided the requirements of the specifications are met.

The bidder agrees, if awarded the contract, to commence and complete the work within the time specified in the bid documents. The bidder acknowledges receipt of the following addenda:

Addenda No. _____ Date of Addenda _____
Addenda No. _____ Date of Addenda _____
Addenda No. _____ Date of Addenda _____

Enclosed is a Bid Bond in the amount of _____
(Dollar Amount or Percentage of Bid)

Type of Business Organization

The bidder, by checking the applicable box, represents that it operates as () a corporation incorporated under the laws of the State of _____, () an individual, () an LLC, () a partnership, () a nonprofit organization, or () a joint venture. If a partnership or joint venture, identify all parties on a separate page.

This project is NOT Federally Funded

Company Name

BID PROPOSAL
(CERTIFICATION)
Continued

SUBJECT: Invitation to Bid No. 2022C045

PROJECT TITLE: GWWTf Aeration System and Blower Upgrades Project (WM.00159)

Date

Alaska Contractor's License Number

Company Name (Printed)

Employer's Tax Identification Number

Authorized Representative Signature

Printed Name & Title

Company **Mailing** Address

Company Phone Number

City, State, Zip Code

Company Fax Number

Company **Physical** Address
(if different from mailing address)

Company Email Address

City, State, Zip Code

END OF ADDENDUM NO. 2