

# MUNICIPALITY OF ANCHORAGE PURCHASING DEPARTMENT

PHONE (907) 343-4590 P.O. Box 196650 ANCHORAGE, ALASKA 99519-6650

DATE OF INVITATION <b>January 11, 2023</b>	TIME AND DATE OF OPENING <b>2:00 PM Local Time, February 1, 2023</b>
---	---

## ADDENDUM No. 1

**TO INVITATION TO BID No. 2023C003**

**DATE ISSUED: January 17, 2023**

**TITLE: Oscar Anderson Museum Roof Repair.**

The following changes and/or additions are hereby made to subject Invitation to Bid:

- 1. INCORPORATE:** the attached changes, consisting of one page, identified as Addendum No. 1, dated January 17, 2023.

All other terms, conditions and specifications remain unchanged.

An electronic (.pdf) copy of the Invitation to Bid is available at Municipality of Anchorage, Purchasing Office website; (<http://www.muni.org/Departments/purchasing/Pages/bidding.aspx>) Should you choose to obtain a copy of the Invitation to Bid from the website; it is your responsibility to periodically check the website for addends.

**THIS ADDENDUM MUST BE ACKNOWLEDGED IN SPACE PROVIDED ON BID PROPOSAL SHEET OR SIGNED AND RETURNED TO PURCHASING PRIOR TO TIME SET FOR BID OPENING IN ACCORDANCE WITH ANCHORAGE MUNICIPAL CODE 7.20.020C.**

Municipality of Anchorage reserves the right to accept or reject bids. Prices quoted must be F.O.B. Destination. Municipality is exempt from Federal Excise Tax. Bids shall be submitted to the Purchasing Office prior to time set for opening. Any bids not received by the Purchasing Office prior to that time will not be considered and will be returned.

**PLEASE ACKNOWLEDGE AND RETURN THIS ADDENDUM PRIOR TO THE DATE AND TIME SHOWN ABOVE OR YOUR BID MAY BE REJECTED.**

VENDOR NAME \_\_\_\_\_

MUNICIPALITY OF ANCHORAGE

SIGNATURE \_\_\_\_\_

Chris Hunter

DATE OF BID \_\_\_\_\_

Chris Hunter  
Deputy Purchasing Director

**Invitation to Bid PROJECT #2023C003  
Oscar Anderson Museum Roof Repair**

**Addendum No.1  
1/17/2023**

**TO: PLANHOLDERS**

The contract documents for the referenced project are clarified and amended as follows:

**MODIFICATIONS/CLARIFICATIONS:**

No Modifications/Clarifications

**DRAWINGS:**

No changes to Drawings.

**RESPONSES TO BIDDERS' QUESTIONS:**

**Question 1:** Is 26 Gauge standing seam acceptable?

**Response 1:** The specified product is not available in 26 Gauge. Only 22 & 24 Gauge is available. For this project, 24 Gauge is acceptable. For panel coverage assume 12-inches.

**Where any requirements of the Invitation to Bid conflict with an item in an Addendum, the Addendum shall govern. All other terms and conditions of the Invitation to Bid shall remain unchanged and in full force and effect.**

**END OF ADDENDUM NO.1**