

MUNICIPALITY OF ANCHORAGE PURCHASING DEPARTMENT

PHONE (907) 343-4590 P.O. Box 196650 ANCHORAGE, ALASKA 99519-6650

DATE OF INVITATION 4/13/2023	TIME AND DATE OF OPENING 3:00 PM Local Time, May 9, 2023
--	--

ADDENDUM No. 3

TO INVITATION TO BID No. 2023C016

DATE ISSUED: May 2, 2023

TITLE: 100th Ave Surface Rehabilitation- Minnesota Dr. to Victor Rd.

The following changes and/or additions are hereby made to subject Invitation to Bid:

- 1. INCORPORATE:** the attached changes, consisting of one page, identified as Addendum No. 3, dated May 2, 2023.

All other terms, conditions and specifications remain unchanged.

An electronic (.pdf) copy of the Invitation to Bid is available at Municipality of Anchorage, Purchasing Office website; (<http://www.muni.org/Departments/purchasing/Pages/bidding.aspx>) Should you choose to obtain a copy of the Invitation to Bid from the website; it is your responsibility to periodically check the website for addends.

THIS ADDENDUM MUST BE ACKNOWLEDGED IN SPACE PROVIDED ON BID PROPOSAL SHEET OR SIGNED AND RETURNED TO PURCHASING PRIOR TO TIME SET FOR BID OPENING IN ACCORDANCE WITH ANCHORAGE MUNICIPAL CODE 7.20.020C.

Municipality of Anchorage reserves the right to accept or reject bids. Prices quoted must be F.O.B. Destination. Municipality is exempt from Federal Excise Tax. Bids shall be submitted to the Purchasing Office prior to time set for opening. Any bids not received by the Purchasing Office prior to that time will not be considered and will be returned.

PLEASE ACKNOWLEDGE AND RETURN THIS ADDENDUM PRIOR TO THE DATE AND TIME SHOWN ABOVE OR YOUR BID MAY BE REJECTED.

VENDOR NAME _____

MUNICIPALITY OF ANCHORAGE

SIGNATURE _____

Chris Hunter

DATE OF BID _____

Chris Hunter
Deputy Purchasing Director

**Invitation to Bid PROJECT# 2022C016
100th Ave Surface Rehabilitation- Minnesota Dr. to Victor Rd.**

**Addendum No. 3
May 2, 2023**

RESPONSES TO BIDDERS' QUESTIONS:

1. Question:

Question(s):

Addendum 2 –

1. Question: What is the condition of the pipe?

Response: Pipes shall be considered partially deteriorated, per MASS Section 55, Article 26.3C Structural Requirements.

Original Specifications:

SECTION 55.26 CURED IN PLACE PIPE (CIPP) LINING Article
26.3 Materials Replace #1 of C. Structural Requirements with the following:
All pipes shall be considered fully deteriorated.

Being that there is a hole in the existing pipe can you confirm that we are to base this off of partially deteriorate pipe condition as per addendum 2 and not fully deteriorated pipe condition as per original specifications.

Response:

Bid per original bid documents. All pipes shall be considered fully deteriorated.

Where any requirements of the Invitation to Bid conflict with an item in an Addendum, the Addendum shall govern. All other terms and conditions of the Invitation to Bid shall remain unchanged and in full force and effect.

END OF ADDENDUM NO. 3