

MUNICIPALITY OF ANCHORAGE PURCHASING DEPARTMENT

PHONE (907) 343-4590 P.O. Box 196650 ANCHORAGE, ALASKA 99519-6650

DATE OF INVITATION	TIME AND DATE OF OPENING
April 28, 2023	4:00 PM Local Time, May 19, 2023

ADDENDUM No. 2

TO INVITATION TO BID No. 2023C019

DATE ISSUED: May 10, 2023

TITLE: Russian Jack Springs Trail and Bridge Improvements

The following changes and/or additions are hereby made to subject Invitation to Bid:

- 1. REPLACE:** MASS Special Provisions page 24 (SP-24) with MASS Special Provisions page 24R (SP-24R)
- 2. INCORPORATE:** the attached changes, consisting of one page, identified as Addendum No. 2, dated May 10, 2023.

All other terms, conditions and specifications remain unchanged.

An electronic (.pdf) copy of the Invitation to Bid is available at Municipality of Anchorage, Purchasing Office website; (<http://www.muni.org/Departments/purchasing/Pages/bidding.aspx>) Should you choose to obtain a copy of the Invitation to Bid from the website; it is your responsibility to periodically check the website for addends.

THIS ADDENDUM MUST BE ACKNOWLEDGED IN SPACE PROVIDED ON BID PROPOSAL SHEET OR SIGNED AND RETURNED TO PURCHASING PRIOR TO TIME SET FOR BID OPENING IN ACCORDANCE WITH ANCHORAGE MUNICIPAL CODE 7.20.020C.

Municipality of Anchorage reserves the right to accept or reject bids. Prices quoted must be F.O.B. Destination. Municipality is exempt from Federal Excise Tax. Bids shall be submitted to the Purchasing Office prior to time set for opening. Any bids not received by the Purchasing Office prior to that time will not be considered and will be returned.

PLEASE ACKNOWLEDGE AND RETURN THIS ADDENDUM PRIOR TO THE DATE AND TIME SHOWN ABOVE OR YOUR BID MAY BE REJECTED.

VENDOR NAME _____

MUNICIPALITY OF ANCHORAGE

SIGNATURE _____



DATE OF BID _____

Nicole Martindale
Deputy Purchasing Director

**Invitation to Bid PROJECT# 2023C019
Russian Jack Springs Trail and Bridge Improvements**

**Addendum No. 2
May 10, 2023**

RESPONSES TO BIDDERS' QUESTIONS:

1. Question:

The project plans show a pedestrian bridge (page S2) with a 12' 2" clear width. The specification section on page SP-24 notes an inside clear of 10' 6". Will you please confirm which dimension should be considered?

Response:

The prefabricated bridge width is 12'-2" inside clear and the special provision on page SP-24 should be updated to 12'-2".

Where any requirements of the Invitation to Bid conflict with an item in an Addendum, the Addendum shall govern. All other terms and conditions of the Invitation to Bid shall remain unchanged and in full force and effect.

END OF ADDENDUM NO. 2