



Municipality of Anchorage

Dave Bronson, Mayor
Purchasing Department

August 5, 2022

REQUEST FOR PROPOSAL

RFP 2022P029

Resource Recovery Center

ADDENDUM NO. 1

Please make the following changes to the subject project.

- 1. ADD:** The following attachments
 - Attachment 7 - 1986 CTS Admin Addition and Alterations
 - Attachment 8 - 1987 Central Transfer Facility COMBINED
 - Attachment 9 - Combined 1982 Refuse Equipment and Warm Storage Drawings
 - Attachment 10 - Tipping Floor Thickness from 2018C003 ITB Docs & Drawings 2-2-18
- 2. ADD:** Additional Site Visit: 10:00 A.M. Local Time, August 10th, 2022
- 3. Questions and Answers**

Where any requirements of the Request for Proposal conflict with an item in an Addendum, the Addendum shall govern.

All other terms and conditions of the Request for Proposal shall remain unchanged and in full force and effect.

This addendum and other documents related to this project are available by visiting the Purchasing office website at:

<http://www.muni.org/Departments/purchasing/Pages/bidding.aspx>

If you have previously submitted a response to this project and wish to have it returned, please email that request to wwpur@muni.org

All other terms and conditions remain unchanged.

Sincerely,

Chris Hunter

Chris Hunter
Deputy Purchasing Director

Questions & Answers:

Question 1: How is the tip floor building heated? Is there in-floor heating in the concrete? If so, please share what you know about the system- is it electric lines, or heated water? How deep are the lines? How thick is the concrete?

Answer 1: There is no radiant in-floor heating in the tipping building. The tipping floor consists of a combination of a 6” reinforced slab on grade and an 8” wear slab over 6” reinforced slab. See new attachments.

Question 2: A copy of the drawings/schematic for the heat system would be very helpful. Please provide all facilities drawings, including construction and utilities, for the ‘warm storage’ and ‘tip floor’ buildings.

Answer 2: See new attachments